

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 7125-1130:214

Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Honeywell International Inc., 1500 W. Dundee Rd., Arlington Heights, IL 60004-1472
Contact: Bob Hodgson (847) 797-4403 FAX (847) 797-3664

DESIGN: Models XLSG1-V15, XLSG1-V30, XLSG1-V60, XLSG1-V75, XLSG1-V110, XLSG1F-V15, XLSG1F-V30, XLSG1F-V60, XLSG1F-V75, XLSG1F-V110, XLSG1R-V15, XLSG1R-V30, XLSG1R-V60, XLSG1R-V75, XLSG1R-V110, XLSG1RF-V15, XLSG1RF-V30, XLSG1RF-V60, XLSG1RF-V75, and XLSG1RF-V110 single gang strobe lights, *followed by -R, -F or none. *The suffix -F refers to a silk-screened word 'FIRE' on the strobe housing (not on the lens). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 24-30 VDC
Candela: 15cd, 30cd, 60cd, 75cd, 110cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela rating, and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control units. For indoor use and wall mount only. Refer to listee's Installation Instruction Manual for details.

XLFF: *7125-1591:203 Formerly 7125-1388:232

*Rev. 03-30-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**